

Recognized by Pollution Control Board, Assam

AMBIENT AIR ANALYSIS REPORT

Rep.No. 161119_14010029_01_676 ^{9/11}

Date: 19/11/2016

Name & Address:

M/s. Assam Plywood Ltd.
(Signature Estates)
B.K. Kakoti Road,
Mouza: Ulubari, Dist: Kamrup,
Guwahati- 781007, Assam.

SL. NO.	DATE OF SAMPLING	LOCATION/ SOURCE	WEATHER	PARAMETERS			
				PM ₁₀ (µg/m ³)	PM _{2.5} (µg/m ³)	NO _x (µg/m ³)	SO ₂ (µg/m ³)
i)	15/11/16	Near Main Gate	Clear	58.1	27.3	12.9	7.1
ii)		Near Centre Point		60.5	29.9	11.4	5.0

Remarks: - Parameters are within the permissible limit.

NATIONAL AMBIENT AIR QUALITY STANDARDS:

Sl. No.	Pollutant	Time Weighted Average	Concentration in Ambient Air
			Industrial, Residential, Rural and Other Area
1	Sulphur Dioxide (SO ₂), µg/m ³	24 hours	80
2	Nitrogen Dioxide (NO ₂), µg/m ³	24 hours	80
3	Particulate Matter (PM ₁₀), µg/m ³	24 hours	100
4	Particulate Matter (PM _{2.5}), µg/m ³	24 hours	60

Envision Enviro Technologies North East, Guwahati



(Quality control Manager)

Note: i) The results relate only to the parameters tested
ii) The test report shall not be reproduced except in full, without written approval of laboratory.

Recognized by Pollution Control Board, Assam.

D.G SET NOISE LEVEL MEASUREMENT REPORT

Rep.No. 161119_14010029_06A_677
911

Date: 19/11/2016

Name & Address:

M/s. Assam Plywood Ltd.
(Signature Estates)
B.K. Kakoti Road,
Mouza: Ulubari, Dist: Kamrup,
Guwahati- 781007, Assam.

SL. NO.	DATE OF SAMPLING	LOCATION /SOURCE	NOISE LEVEL in dB(A)Leq
i)	15/11/16	125 KVA - DG Set	65.8

Remarks: Noise level is carried out during day time at a distance 1metre from the enclosure surface.

DG Set Noise Standards:

Noise limit viz. 75 dB(A) at 1m distance.

Envision Enviro Technologies North East, Guwahati.



(Quality Control Manager)

Note: i) The results relate only to the parameters tested
ii) The test report shall not be reproduced except in full, without written approval of laboratory.

Recognized by Pollution Control Board, Assam

AMBIENT NOISE LEVEL MEASUREMENT REPORT

Rep.No. 161119_14010029_06A_678 ⁹¹¹

Date: 19/11/2016

Name & Address:

M/s. Assam Plywood Ltd.
(Signature Estates)
B.K. Kakoti Road,
Mouza: Ulubari, Dist: Kamrup,
Guwahati- 781007, Assam.


SL. NO.	DATE OF SAMPLING	LOCATION /SOURCE	NOISE LEVEL in dB(A)Leq
i)	15/11/16	Near Main Gate	50.8
ii)		Near Centre Point	46.1

Remarks: Noise level are carried out during day time.

Ambient Noise Standards:

Area Code	Category of area	Limits in dB(A) Leq	
		Day (6:00 am to 10:00 pm)	Night (10:00 pm to 6:00 am)
A	Industrial Area	75	70
B	Commercial Area	65	55
C	Residential Area	55	45
D	Silence Zone	50	40

Envision Enviro Technologies North East, Guwahati.



(Quality Control Manager)

Note: i) The results relate only to the parameters tested
ii) The test report shall not be reproduced except in full, without written approval of laboratory.

Recognized by Pollution Control Board, Assam

STACK ANALYSIS REPORT

Rep.No. 161119_14010029_02_679

Date:19/11/2016

Name & Address:

M/s. Assam Plywood Ltd.
(Signature Estates)
B.K. Kakoti Road,
Mouza: Ulubari, Dist: Kamrup,
Guwahati- 781007, Assam.

SL. NO.	DATE OF SAMPLING	STACK DESCRIPTION	PARAMETERS	REMARKS
			Particulate Matter (g/kwhr)	
i)	15/11/16	Stack attached to DG set - 125 KVA	0.09	-Data is within the permissible limit

Emission Standards for Diesel Engine for generator set :

Engine Power(P)	Parameter	Standards
75KW<P≤800KW	Particulate Matter	0.2 g/kwhr

Envision Enviro Technologies North East, Guwahati



(Quality Control Manager)

- Note: i) The results relate only to the parameters tested
ii) The test report shall not be reproduced except in full, without written approval of laboratory.